

POLICY
Approved 11/15/02

Fat, Oil and Grease (FOG) Generators

Any business that generates and discharges FOG into the collection system of GLPWA will be subject to testing and be required to meet GLPWA standards.

Facilities:

Businesses with potential to generate FOG are required to provide separate discharge lines for FOG producing activities (kitchens) and restroom facilities. They will also be required to provide a GLPWA approved sample port on the FOG discharge line.

Standard:

Business will be required to maintain FOG at 100 mg/l or less.

Testing:

FOG testing will be performed on a schedule appropriate to the business. The schedule will be established by GLPWA. Costs of the test will be the expense of the business. As long as entity stays within compliance testing will not be more than 4 times a year.

Implementation:

This policy is to be in effect as of the date of approval.

GLPWA will test existing facilities immediately upon approval of policy and work with entities over a 3 month period before any warnings or fines are issued. Entities connecting to GLPWA after implementation of this policy will be subject to the entire policy upon date of connection.

Penalty:

Any entity found not meeting the maximum FOG requirement of 100 mg/l will be given a written warning for their first offense.

Subsequent offenses will be subject to penalties up to:

2 nd offense	\$ 500
3 rd offense	\$1,500
4 th offense	Disconnection of service

An entity receiving a warning or penalty will be given 30 days from date of notification to correct the problem.

Customer Signature

Date